

GREENSBORO FIRE DEPARTMENT
FIRE PREVENTION BUREAU
1514 N. Church Street
Greensboro, N. C. 27405
373-2177

To: Chief of Fire Prevention Bureau, City of Greensboro, N. C.

Application is hereby made by the undersigned for a permit to

X Remove Underground Tank(s)

 Abandon Underground Tank(s) in or on the premises know as:

Piedmont Truck & Body 533 Plt # 57 - 650
(Business Name and Address)

1. Tank Contractor: Four Seasons Industrial Services, Inc.

Contractor's Address: 3107 S. Elm-Eugene St.; Greensboro, NC 27406

Number, size and product type of tanks: (3) 10,000

diesel underground storage tanks.

2. Permit shall be obtained for the removal or abandonment of underground tanks in place prior to beginning work.
3. Tank contractor shall be licensed as a General Contractor by City Tax Collections.
4. Removal and abandonment of underground tanks in place shall comply with all applicable codes and regulations including the Fire Code, Guilford County Health Regulations, N.F.P.A. 327, and A.P.I. Publication 1604.
5. Notify Fire Prevention at 373-2177 and Guilford Environmental at 373-3771 prior to removal or abandonment in place.
6. For tank removal or abandonment in place all liquids shall be removed from the tank(s) and properly disposed of in accordance with applicable laws.
7. Prior to removal or abandonment in place tanks shall be purged or rendered inert. Purging or inerting shall be conducted in accordance with applicable standards and regulations. For purging the vapors shall not exceed 20% of the lower flammable limit. For inerting the oxygen content shall be below 8%. Tank contractor shall have the proper operating meters, combustible gas indicator and/or oxygen meter at each job site.

Note: Perchloroethylene will not be allowed as an inerting agent.

8. Tanks which have been removed from the ground shall be promptly removed from the premises to a proper facility. Tanks shall be labeled with legible letters at least 2 inches high similar to the following:

TANKS HAS CONTAINED LEADED GASOLINE
NOT VAPOR FREE
NOT SUITABLE FOR STORAGE OF FOOD
OR LIQUIDS INTENDED FOR HUMAN OR ANIMAL CONSUMPTION
DATE OF REMOVAL; MONTH/DAY/YEAR

9. Tanks to be transported in accordance with all applicable Local, State and Federal regulations. Tank openings to be plugged or capped with one plug having a 1/8 inch vent hole to prevent the tank from being subjected to excessive differential pressure. Tanks to be secured on a truck for transportation to the storage or disposal site with the 1/8 inch vent hole located at the uppermost point on the tank.
10. Tank contractor shall complete and submit the attached Guilford County form upon completion of removal or abandonment of tanks. Information submitted to be accurate and detailed.

I understand and consent to the above stipulated conditions upon which this permit is granted. Failure to obtain permit and comply with regulations may render you liable to the penalties provided by Law.

Michael D. Stenner
Applicant

Bill Smith

J.C. Lemonds
Fire Inspector

Date: 5-21-91

Date: 5-21-91

Phone: Day 277-2718 Night 277-2720

Permit Granted X Denied

cc. Guilford County Health Department

5-5-89

GREENSBORO FIRE DEPARTMENT
FIRE INSPECTION REPORT

STREET NUMBER		DIR		STREET NAME										TYPE		BUILDING UNIT		GENERAL INSP. DATE																			
533				PLOT T										ST																							
9	13	14	15	16											31	32	33	34	37																		
LAST INSP. DATE		BC OCCUPANCY		NFPA OCCUPANCY		COMPLEX		CONST		SPRINKLERS		STAND PIPES		DETECTORS		ALARM SYS		SPEC SYS		YR. CONST.		STORIES		FIRE EXT.		L-LINE P-PREV											
38		40		41		43 44		45		46		47		48		49		50		51		52		53		54		55		56		57					
LAST INSP. BY		SQ. FT. GROUND FLOOR				MAX. OCCUPANT LOAD				REQ. EXITS		SPEC INSTR		DUE DATE				INSPECTION PERIOD				DISTRICT															
58		63				64				67		68		69		70				75				76				77		78				79		80	

28	2

NOTICE OF FIRE & SAFETY HAZARDS: You are hereby notified that an inspection of your premises has disclosed the following fire safety hazards and/or violations of the provisions of appropriate local or state codes.

CODE		TYPE	COUNT	DESCRIPTION	APPR
				Witnessed removal of (3) ² 3,000 gal. diesel tanks. All parts of permit carried out. Tanks looked in good shape. Four Seasons taking tanks to Patterson Ave. for deposit. 1- 6,000 gal tank. Samples taken also results will be sent to F.D.	

9 10 13
22 23 24 25 26
55 56

ORDER TO COMPLY: As such conditions are contrary to law, you are hereby required to correct said conditions immediately upon receipt of this notice. An inspection to determine whether you have complied will be conducted on or before Failure to comply with the foregoing order before the date of such reinspection may render you liable to the penalties provided by law for such violation. FIRE PREVENTION BUREAU - PHONE 373-2177

REINSPECTION DATE
34

FEES AND PENALTIES INCLUDE: REINSPECTION FEES, AND/OR CITATIONS, OR CRIMINAL SUMMONS.

REINSPECTION DATE	
34	3

BUSINESS PHONE

EMERGENCY PHONE	
59	

BUILDING UNIT IDENTIFICATION

OCCUPANT'S COPY